



VALIDACIÓN CERTIFICADO

SM SERVIMETERS



PRODUCT CONFORMITY CERTIFICATE

SCHEME 5 – CONTINUOUS MARK

CERTIFICATE NUMBER: PROD-SM00559-1

SERVIMETERS SAS

Certifies that:

THE PRODUCTS

INDUCTIVE VOLTAGE TRANSFORMERS

Whose references indicated in the Annex, are manufactured by RYMEL INGENIERIA ELECTRICA SAS, Located in: Paraje el Noral , Autopista Norte, Copacabana, Antioquia

Marketed by:

RYMEL ELECTRICAL ENGINEERING SAS

NIT: 890.919.437 - 1

Located in:

Noral area, North Highway, Copacabana, Antioquia

They comply with the requirements of the standards: NTC 5933:2024 (IEC 61869-1:2023) - NTC 2207:2012 (IEC 61869-3:2011) - IEEE std C57.13:2016

Issue Date: 2022-07-05

Expiration Date: 2028-07-01

Modification date: 2026-01-16

Renewal date: 2025-07-01

APPROVAL OF THE CERTIFICATE

Engineer Luisa Fernanda Toro Ríos
General manager

Servimeters SAS Observations:

- 1- This certificate covers only the related product references.
- 2- The validity of this certificate during its term is subject to compliance with and the outcome of the annually scheduled surveillance evaluations.
- 3- Any modification to this certificate, as well as any misuse thereof, is void and subject to legal penalties.
- 4- This Product Certificate does not imply any judgment regarding products other than those mentioned in the list of certified references, nor regarding other products manufactured, marketed, integrated, or imported by the certificate holder.
- 5- Modification date 2024-02-27 corresponds to the inclusion of IEEE std C57.13:2016
- 6- Modification date 2025-07-01 corresponds to the update of the versions of the technical standards: NTC 5933:2024 (IEC 61869-1:2023)
- 7- Renewal date 2025-07-01
- 8- Modification date 2025-08-14 corresponds to the updating of internal references, clarification of the connection type and reorganization of information relating to the relationship and possible combinations of primary and secondary voltage values.
- 9- Modification date 2026-01-16 corresponds to the Extension of the Scope Voltage Level 36kV

www.servimeters.com

Carrera 20C No 74A-10 Barrio San Felipe
Bogotá D.C – Colombia, PBX (57) (601) 210 0833
Cel: (57) 320 888 2407 - servicioalcliente@servimeters.com
Compruebe su validez escaneando el código QR o comuníquese con nosotros.



ISO/IEC 17065:2012
17-CPR-002



VALIDACIÓN CERTIFICADO

SM SERVIMETERS



CERTIFICATE NUMBER: PROD-SM00559-1

EXHIBIT

INDUCTIVE VOLTAGE TRANSFORMERS

GUY	Inside		Abroad	
Reference	TPIM2	TPIM1	TPEM2	TPEM1
Maximum voltage (kV)	From 17.5 to 36			
Insulation level (kV)	17.5/38/95 24/50/125 36/70/170			
Nominal primary voltage (V)	From 4160 to 36500	From 4160/√3 to 36500/√3	From 4160 to 36500	From 4160/√3 to 36500/√3
Nominal secondary voltage (V)	110 – 115 - 120	110/√3 - 115/√3 or 120/√3	110 – 115 - 120	110/√3 - 115/√3 or 120/√3
Accuracy class	0.2, 0.5, 3P, 6P			
Frequency (Hz)	50/60			
Nominal power, burden (VA)	1, 2.5, 5, 10, 15, 25, 30, 50			
Type of insulation	Epoxy resin			
Connection	F - F	F - T	F - F	F - T
Use	Inside		Abroad	
Referential	NTC 5933:2024 (IEC 61869-1:2023) - NTC 2207:2012 (IEC 61869-3:2011)			

www.servimeters.com

Carrera 20C No 74A-10 Barrio San Felipe
 Bogotá D.C – Colombia, PBX (57) (601) 210 0833
 Cel: (57) 320 888 2407 - servicioalcliente@servimeters.com
 Compruebe su validez escaneando el código QR o comuníquese con nosotros.



ISO/IEC 17065:2012
 17-CPR-002



VALIDACIÓN CERTIFICADO

SM SERVIMETERS



GUY	Inside		Abroad	
Reference	TPIM2	TPIM1	TPEM2	TPEM1
Maximum voltage (kV)	From 15.5 to 36.5			
Insulation level (kV)	15.5/34/110 25.5/50/150 36.5/70/200			
Nominal primary voltage (V)	From 4160 to 36500	From 4160/√3 to 36500/√3	From 4160 to 36500	From 4160/√3 to 36500/√3
Nominal secondary voltage (V)	110 – 115 - 120	110/√3 - 115/√3 or 120/√3	110 – 115 - 120	110/√3 - 115/√3 or 120/√3
Accuracy class	0.15; 0.3; 0.6; 1.2			
Frequency (Hz)	50/60			
Nominal power, burden (VA)	W (12.5) X (25.0) M (35.0) And (75.0)			
Type of insulation	Epoxy resin			
Connection	F - F	F - T	F - F	F - T
Use	Inside		Abroad	
Referential	IEEE std C57.13:2016			

End of certificate.www.servimeters.com

Carrera 20C No 74A-10 Barrio San Felipe
 Bogotá D.C – Colombia, PBX (57) (601) 210 0833
 Cel: (57) 320 888 2407 - servicioalcliente@servimeters.com
 Compruebe su validez escaneando el código QR o comuníquese con nosotros.



ISO/IEC 17065:2012
 17-CPR-002